
P: (631) 665-9300 • F: (631) 491-0897 • WWW.ITPNY.NET

FIG. 280S ADJUSTABLE PIPE ROLL STAND, **CARBON STEEL**

FIG. 280SS ADJUSTABLE PIPE ROLLER STAND, **304 STAINLESS STEEL**

Ordering:





Material: Carbon steel chair base plate and axle with cast iron roller.

Finish: Plain, galvanized or painted.

Service: Designed for the support of pipe where longitudinal

movement may occur due to expansion and contraction,

and where vertical adjustment is necessary.

Approvals: Complies with Federal Specification WW-H-171-E

(Type# 47), A-A-1192A (Type# 46) and Manufacturers' Standardization Society MSS SP-58 and SP-69 (Type# 46).

Specify roller size, figure number and finish. Please remember to consider insulation thickness when sizing rollers.

Notes:

*Stainless steel adjustable roller chair supports are recommended for applications where protection from

corrosive environments is needed.

Available domestic

PIPE SIZE	A	В	C MIN	C MAX	D	E	F	G	WGT EACH (lbs)	MAX REC LOAD (lbs)
2	6 ⁷ /8	6	4 3/4	5 ⁵ /8	3 ⁷ /8	1	1	1/2	11.00	390
2 1/2	6 ⁷ /8	6	5	5 7/8	3 ⁷ /8	1	1	1/2	11.00	390
3	6 ⁷ /8	6	⁵⁵ / ₁₆	6 ⁹ /16	3 ⁷ /8	D 1 A	1	1/2	11.00	390
3 1/2	6 ⁷ /8	6	⁵⁹ / ₁₆	6 ⁷ /16	3 ⁷ /8	A 1/A	1/1	1/2	11.00	390
4 1 0	8 1/2	6	63/16	7 ⁷ /16	5 ¹ / ₈	RANTICT	1	1/2	13.10	950
5	8 1/2	6	63/4	8	5 ¹ /8	1	1	1/2	13.10	950
6	8 1/2	6	7 1/4	8 1/2	5 ¹ /8	1	1	1/2	13.10	950
8	10 ¹ / ₂	7 1/2	10 ¹ /8	11 11/16	7 ³ /8	1 1	1	3/4	29.00	2100
10	10 ¹ / ₂	7 1/2	11 ³ / ₁₆	12 ³ / ₄	7 ³ /8	1	- / /1 <u> </u>	3/4	29.00	2100
12	12 ¹ / ₂	8 1/4	12 ³ / ₄	14 ¹ /8	9 1/2	RODI GI	1	7/8	40.00	3075
14	12 1/2	8 1/4	13 ³/8	14 ³ /8	9 ¹/	1	4	7/8	40.00	3075
16	14 5/8	10	15 ³/8	17 1/4	11 ¹/8	1	1	1 1/8	63.84	4980
18	14 5/8	10	16 ³ / ₈	18 ¹/₄	11 ¹ /8	2 1 /))1	1 1/8	63.84	4980
20	14 5/8	10	17 ³ / ₈	19 1/4	11 ¹ /8		1	1 1/8	63.84	4980
24	15 ³ / ₄	10	19 ¹/4	21 1/4	12 ¹ / ₄	KUDĐUGI	1_1_	1 ¹ / ₄	71.00	6100
30	19 ¹ / ₂	10 ³ / ₄	24 7/16	26 11/16	15 ³ / ₄	1	11/2	1 ³ / ₄	125.28	7500

Project	Approval Stamp			
Project:	INDUSTRIAL)	Notes:		
Address:	Contractor:	THREADED PRODUCTS		
Date:	Engineer:			
Approved	INDUCTORAL			